


NOT to scale



House served by lagoon

Existing home

Heavy Timber

200'

Cleanouts
no more than
100' apart

50'

100'

50'

WATER
SUPPLY

100'

PROPERTY LINE

75'

100'

Septic tank recommended and
if used may be able to reduce
the size of the lagoon by 20%.
(See section on sewage tanks and #6
on waste stabilization ponds)

Warning sign
designating the nature
of the facility

50'

The discharge line
may be placed
on the uphill
side to achieve
the 100'

Stream, Water Course, Lake or Impoundment